

Boil Notice Update

Boil Water Update

April 24, 2026

On April 23, 2026, the Village of San Leanna public water system, PWS #2270017, issued a precautionary Boil Water Notice to inform customers that the water from this public water system was required to be boiled prior to use for drinking water or human consumption purposes due to a failed chlorine regulator and lower than usual chlorine residual levels.

Water system staff worked quickly to replace the regulator and restore the quality of the water to normal operating levels yesterday afternoon.

Upon review of the water tests collected, it was found that chlorine residuals reached a level of 0.3 mg/L during that window, but did **not** actually fall below the 0.2 mg/L trigger for a required Boil Notice.

Because the Boil Notice was issued to water system customers before this information was confirmed, the Village is working to provide TCEQ with all required documents which may take until Tuesday, April 28.

If you have questions concerning this matter, you may contact Rebecca Howe at 512-280-3898 or village@sanleannatx.com.